

Annexure- C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 06

Dated: 28/10/2026

It is certified that an inspection team headed by

.....Rahul Mahour chemist..... (Name of Officers with designation)

from.....Public Health Engineering Department.....PHED

inspected theSomya Public School, Sakshi Premisu, A.B. Road Myang

(Name & Address of the school) on27/10/2026.....(date of inspection) and on the basis

of Water Test Report (Attached) bearing no.....06.....

dated.....28/10/2026.....ofP.H.E.D. Lab..... (PHED Lab)

certified that the

.....Somya Public School.....(Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains

the hygienic sanitation condition in the school building & the campus as per norms

prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till28/10/2026 to 27/10/2027

Signature with Seal:.....

Name :Rahul Mahour.....

Designation :Chemist.....

Name & Address of the Office / Department :PHED

To

.....Principal.....
.....Somya Public School, A.B. Road Myang
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

WATER TESTING LABORATORY

Public Health Engineering Department Guna (M.P.)

ANALYSIS REPORT

1 SENDER Name & Address <u>m/s Somya Public School</u> Block & Village <u>Guna</u>	2. PARTICULARS OF Place of collection & details of sample SAMPLE : (i) <u>m/s Somya Public School,</u> (ii) <u>Sakshi Premises A.B Road</u> (iii) <u>Myoga Guna</u> (iv) <u>(Twp)</u> (v) _____ Date _____ Date _____ Date _____ Date _____ Date _____
3 PARTICULARS TO BE FILLED IN THE LABORATORY : Reference No. _____ 4 A. Date & time of receipt <u>27/10/26</u> (B) TESTED ON <u>28/10/2026</u> C. Laboratory Sample id _____ (D) NATURE OF STUDY <u>CHEMICAL/BACTERIOLOGICAL</u>	

S.NO	Characteristics	Units	As per BIS -10500:2012 FOR Drinking Water		Results				
			Acceptable	cause for rejection	I	II	III	IV	V
1	Iron	mg/L	1.0	1.0	0.00				
2	Nitrates	mg/L	45	45	8				
3	Arsenic	mg/L	0.01	0.01	-				
4	Fluoride	mg/L	1.0	1.5	with 1.0				
5	Chlorides	mg/L	250	1000	55				
6	Total Dissolved Solids	mg/L	500	2000	310				
7	Alkalinity	mg/L	200	600	128				
8	Calcium As "Ca"	mg/L	75	200	73.6				
9	Magnesium as "Mg"	mg/L	30	100	22.08				
10	Residual Cl ₂	mg/L	0.2	1.0	0.00				
11	Sulphate	mg/L	200	400	-				
12	pH Value	pH Scale	6.5 to 8.5	No relaxation	7.8				
13	Turbidity	NTU	1	5	2.2				
14	Total Hardness	mg/L	200 as CaCO ₃	600 as CaCO ₃	276				
15	E-Coli	100ml	0.00	0.00	0.00				
16	Coli form	100ml	0.00	0.00	-				
17	Colour	pl Cobalt Scale	5.0	15	BDL				
18	Temperature	°C	-	-	-				
19	Conductivity	Micromhos/cm	-	-	476				
20	Test and odour	-	Unobjectionable	Unobjectionable	Unobj.				
21	Nitrites (P/A Test)	-	Colour Less (A)	Pink colour (P)	-				

Note :- According to the test Water of given Sample is fit / unfit for drinking Purpose.


Chemist
 Sub-division Guna